



For optimum control accuracy, a straight section of duct at least 1.5 duct diameters long and the same diameter as the inlet collar should be installed upstream of the terminal inlet. Sizes 6 through 22 utilize FlowStar™ multi-axis center averaging sensor. Sizes 4 and 5 utilize single-axis, linear averaging multi-point sensor.

TITLE: MODELS: SDR, SDL, SGX, DDR, CFR, CFRQ, CFL, VFR & VFL
WITH ENVIRO-TEC® ELECTRONIC CONTROLS
VOLT vs CFM @ INLET



DRN BY: AWW	DATE: 11/20/92	SCALE: N/A	DRAWING NO.
CKD BY: DB	DATE: 07/31/15	REV: 05	

THIS DRAWING CONTAINS PROPRIETARY DATA.
UNAUTHORIZED DISCLOSURE, REPRODUCTION, OR USE
IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION

DO NOT SCALE DRAWING
DIMENSIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE.
CONTACT FACTORY FOR CERTIFIED DRAWINGS.

15884